

The manufacturer may use the mark:



Revision 2.0 March 25, 2025 Surveillance Audit Due December 01, 2027

ANSI National Accreditation Board ACCREDITED ISO/IEC 17065 PRODUCT CERTIFICATION BODY #1004

Certificate / Certificat Zertifikat / 合格証

MIC 2105141 C003

exida hereby confirms that the:

Floating Ball Valve

Microfinish Valves Private Limited Karnataka - India

Has been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-2

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

PFH/PFD_{avg} and Architecture Constraints must be verified for each application

Safety Function:

The Ball Valve will move to the designed safe position per the actuator design within the specified safety time.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



Evaluating Assessor

Certifying Assessor

Floating Ball Valve -Series 84, 85, 87, 89,

90, 91, 80BK and 81

Certificate / Certificat / Zertifikat / 合格証 MIC 2105141 C003

Systematic Capability: SC 3 (SIL 3 Capable) Random Capability: Type A, Route 2_H Device

PFH/PFD_{avg} and Architecture Constraints must be verified for each application

Systematic Capability:

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets exida criteria for Route 2_H .

Versions:

VCI SIOIIS.				
Valve Type	End Connection	Bore Sizes	Pressure Class	
FBV Series 84		15 - 300 mm	150#	
FBV Series 85	Flanged / Welded	15 - 300 mm	300#	
FBV Series 87	Flanged / Weided	15 - 150 mm	600#	
FBV Series 89		15 - 65 mm	900#	
FBV Series 90	Flanged / Socket /	15 - 50 mm	1500#	
FBV Series 91	Welded	15 - 50 mm	2500#	
FBV Series 80BK	Screwed	15 - 50 mm	300#	
FBV Series 81	Screwed / Socket / Welded	8 - 50 mm	600# & 800#	
		50 - 150 mm	300#	

IEC 61508 Failure Rates in FIT*

Static Application – Clean Service	λ_{SD}	λ _{su}	$\lambda_{ ext{DD}}$	λ _{DU}
Full Stroke	0	0	0	425
Tight Shut-Off	0	0	0	1161
Open on Trip	0	121	0	304

^{*} FIT = 1 failure / 109 hours

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: MIC 21/05-141 R006 V2R1 (or later)

Safety Manual: 3DD042 REV 01 (or later)



80 N Main St Sellersville, PA 18960

T-109, V5R3