

The manufacturer may use the mark:



Revision 2.0 March 25, 2025 Surveillance Audit Due December 01, 2027



PRODUCT CERTIFICATION BODY

Certificate / Certificat Zertifikat / 合格証

MIC 2105141 C004

exida hereby confirms that the:

Trunnion Mounted Ball Valve

Microfinish Valves Private Limited Karnataka - India

Has been assessed per the relevant requirements of:

IEC 61508: 2010 Parts 1-2

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

PFH/PFD_{avg} and Architecture Constraints must be verified for each application

Safety Function:

The Ball Valve will move to the designed safe position per the actuator design within the specified safety time.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



Evaluating Assessor

Certifying Assessor

Certificate / Certificat / Zertifikat / 合格証 MIC 2105141 C004

Systematic Capability: SC 3 (SIL 3 Capable) Random Capability: Type A, Route 2_H Device

PFH/PFD_{avg} and Architecture Constraints must be verified for each application

Systematic Capability:

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets exida criteria for Route 2_H .

Versions:

Valve Type	End Connection	Bore Sizes	Pressure Class	
TMBV Series T84	Flanged / Welded	50 - 1200 mm	150#	
TMBV Series T85		ies T85 50 - 1200 mm		300#
TMBV Series T87		50 - 1200 mm	600#	
TMBV Series T89		25 - 1200 mm	900#	
TMBV Series T90		25 - 600 mm	1500#	
TMBV Series T91		25 - 400 mm	2500#	

IEC 61508 Failure Rates in FIT*

Static Application – Clean Service	λ _{SD}	λ _{su}	$\lambda_{ ext{DD}}$	$\lambda_{ extsf{DU}}$
Full Stroke	0	0	0	556
Tight Shut-Off	0	0	0	1058
Open on Trip	0	102	0	454

^{*} FIT = 1 failure / 109 hours

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: MIC 21/05-141 R006 V2R1 (or later)

Safety Manual: 3DD042 REV 01 (or later)

Trunnion Mounted Ball Valve - Series T84, T85, T87, T89, T90 and T91



80 N Main St Sellersville, PA 18960